

Unvented Minor Repair Garage - 2008 NEC 511.3

Ceiling - Unclassified where lighter than air fuels are not transferred.

A minor repair facility which is unvented where flammable liquids are not dispensed or transferred shall all be unclassified except an unvented pit area. This area will be designated Class 1 Div 2 and the area 18" above the pit to 3' away from the pit edge shall also be Class 1 Div 2.

