

## Vented Minor Repair Garage - 2008 NEC 511.3

Ceiling - Unclassified where lighter than air fuels are not transferred.

A minor repair facility which is vented where flammable liquids are not dispensed or transferred shall all be unclassified. The pit ventilation shall be within 12" of the pit floor.

Refer to NEC 511.3 for venting requirements.

Floor Level

Unclassified

Vented  
Pit  
Unclassified